



Understanding Passive Fire testing and assessing Passive Fire Systems

Alex Kokorin

Auckland, July-2023





Presentation content


Fire resistance testing 101

- Assessments and formal opinions variations and overseas standards
- On-site assessment/inspection
- Indicators of incorrect installation and recommended actions
- ► ISO17020 3rd Party Inspection accreditation





Fire resistance testing





Fire Lab

Fire curves

ISO 834/AS1530.4/EN/BS curve

UL curve

RABT-ZTV (Car) curve


RABT-ZTV (Train) curve


RWS - Rijkswaterstatt curve

HCM - Modified Hydrocarbon curve

HC - Hydrocarbon curve

Other parametric curves






https://www.promat.com/en/tunnels/your-project/expert-area/159981/international-fire-curves-fire-safety/





Assessments and formal opinions - Overseas standards







Assessments and formal opinions - Overseas standards

Test	Criteria	4m long beam of depth x (mm)		
standard	Criteria	200	300	400
BS476-21	Limiting deflection	200mm	200mm	200mm
EN 1363-1	Limiting deflection	300mm	200mm	150mm
AS1530.4	Limiting deflection	200mm	133mm	100mm





Assessments and formal opinions - Overseas standards


	Tested						
		U/U	C/U	U/C	C/C		
Covered	U/U	Y	N	Ν	N		
	C/U	Y	Y	N	N		
	U/C	Y	Y	Y	N		
	C/C	Y	Y	Y	Y		
Y = acceptable N = not acceptable							

Y = acceptable, N = not acceptable





Test report is always a story of success






























Assessments and formal opinions - Reality







Indicators of incorrect installation - plastic pipes

- Oversized core holes
- > Sealants for plastic pipes
- Pipe or floor waste
- Pipe wall thickness
- > Pipe material







Indicators of incorrect installation - steel pipes

- > Oversized core holes
- Sealants for steel pipes
- Insulation requirements wraps or blankets
- Pipe wall thickness
- Pipe material








Indicators of incorrect installation -Interchangeability - sealants

- > Different expansion rate
- > Different chemical composition
- > Different thermal conductivity
- Manufacturers does not test each other products








Indicators of incorrect installation







FireSLab

Inspection - ISO17020

- General requirements Impartiality, independence and confidentiality
- Structural requirements Administrative and Organization
- Resource requirements Personnel,
 Facilities, equipment, subcontracting
- Process requirements Inspection methods and procedures, Inspection records and reports, Complaints and appeals
- Management system requirements documentation control and QMS (ISO9001)







Inspection - Scope

BRANZ Guide to

Passive Fire Protection in Buildings



SECOND EDITION

CHECKLIST 6: PENETRATION SEALS

- Penetration seal products include: • mastics, in tube or pail, for lineal gap seals (control joints), wall joints
- (perimeter of walls) or pipes
- foams
- puttles mineral boards, with or without a coating
- mortars
- pillows
- wraps
- collars
- sleeves blocks and plugs.

Penetration types include: pipes

- cables in singles, bundles or on cable trays
- ducts, dampers (see above)
- control loints
- lineal gap seals (control joints)
- wall joints (perimeter of walls).

This checklist addresses specific items for the installation of nenetration seals where services pass through fire-rated wall and floor construction: Obtain copies of site installation specification and consent documents.

- Obtain the compartmentation plan.
- Obtain copies of product specification.
- Is the penetration seal approved for the wall/floor type (masonry, plasterboard etc.)?
- Is the penetration seal approved for the penetration and its application (floor waste, plastic pipe, steel pipe, cable tray, control joint)?
- Are wall (or floor) openings (apertures) prepared to the job specification or the requirements of the installer?
- Are any apertures greater than specified dimensions or badly formed (i.e. chipped edges, irregular)? These should be made good with materials that maintain the FRR of the wall (or floor) and are capable of supporting the seal.
- Is the opening structurally sound with lintels as appropriate?
- Is the wall or floor sound and of appropriate ERP?
- Are pipes supported as specified by the manufacturer or tested if report available?
- Seal is installed as per specification:
- Both sides or one side of floor, wall or celling.
- Filled to correct depth for example, mastics and pillows. Either surface mounted or within wall.
- With pipe, cable tray etc. supports at correct spacing from the wall.

- With appropriate backing material if required.
- · With radiation shields or insulation to metal pipes or as per
- specification
- · With correct fixings to the building element. Check penetration label includes (if provided):
- number of the applicable standard
- FRR in minutes
- name and details of the installer
- Installation date
- unique installation reference number
- name of the manufacturer.

Applicable standards: AS 4072.1-2005(R2016),19 AS 1530.4-2005/2014.

Fire and smoke containment barrier and penetration system (to AS 1530.4 and AS 4072.1) FRR: -/60/60

Installed by (company name):	
Phone no: .	

Installation date Installation reference:

> Contact the above in the event of damage or if reinstatement is required





Inspection - Inspection plan

- Inspection activity
- Description
- Equipment
- Acceptance criteria
- > Type of inspection
 - R review of provided documents
 - M monitoring of ongoing activities, no statement of compliance
 - W Whiteness of operation, Inspector shall be notified prior to any activity performed
 - H Hold point. Activity is prohibited without Inspector presence and approval to proceed

Inspection activity	Description	Equipment	Acceptance criteria	Scope of Inspection	Frequency
Type of wall/floor	Wall type shall be as tested/assessed	Visual/ruler /calliper	Same as tested/ assessed	R	10%
Penetration apertures	As per Installation and Product specifications, as tested/assessed	Visual/ruler /calliper	Within tolerances	R	10%
Dimensions and service type	As tested/assessed	Visual/ measuring tape	300mm from separating element	s	10%
Service support	As per Installation and Product specifications, as tested/assessed	Visual/ measuring tape	Within tolerances	w	10%
Penetrate any structural element	Yes/No	Visual	Special permission	M/R	10%
Fire stopping symmetrical, installed both sides or one side only	As per Installation and Product specifications, as tested/assessed	Visual	Same type	M/R	10%
	activity Type of wall/floor Penetration apertures Dimensions and service type Service support Penetrate any structural element Fire stopping symmetrical, installed both sides or one	activityDescriptionType of wall/floorWall type shall be as tested/assessedPenetration aperturesAs per Installation and Product specifications, as tested/assessedDimensions and service typeAs tested/assessedDimensions and service typeAs per Installation and Product specifications, as tested/assessedDimensions and service typeAs tested/assessedDimensions and service typeAs per Installation and Product specifications, as tested/assessedPenetrate any structural elementYes/NoFire stopping symmetrical, installed both sides or one cide onlyAs per Installation and Product specifications, as tested/assessed	activityDescriptionEquipmentType of wall/floorWall type shall be as tested/assessedVisual/ruler /calliperPenetration aperturesAs per Installation and Product specifications, as tested/assessedVisual/ruler /calliperDimensions and service typeAs per Installation and Product specifications, as tested/assessedVisual/ruler /calliperService supportAs per Installation and Product specifications, as tested/assessedVisual/ measuring tapePenetrate any structural elementYes/NoVisualFire stopping symmetrical, installation and Product specifications, as tested/assessedVisual	activityDescriptionEquipmentcriteriaType of wall/floorWall type shall be as tested/assessedVisual/ruler /calliperSame as tested/ assessedPenetration aperturesAs per Installation and Product specifications, as tested/assessedVisual/ruler /calliperSame as tested/ assessedDimensions and service typeAs tested/assessedVisual/ measuring tapeWithin tolerancesDimensions and service typeAs tested/assessedVisual/ measuring tape300mm from separating elementService supportAs per Installation and Product specifications, as tested/assessedVisual/ measuring tapeWithin tolerancesPenetrate any structural elementYes/NoVisualSpecial permissionFire stopping symmetrical, installed both side or one as tested/assesAs per Installation and Product specifications, as tested/assessedSame type	activityDescriptionEquipmentcriteriaInspectionType of wall/floorWall type shall be as tested/assessedVisual/ruler /calliperSame as tested/ assessedRPenetration aperturesAs per Installation and Product specifications, as tested/assessedVisual/ruler /calliperWithin tolerancesRDimensions and service typeAs tested/assessedVisual/ measuring tapeWome from separating elementSService supportAs per Installation and Product specifications, as tested/assessedVisual/ measuring tapeSomm from separating elementSPenetrate any structural elementYes/NoVisualSpecial permissionM/RFire stopping symmetrical, installation and Product specifications, as tested/assessedVisualSame typeM/RFire stopping sides or one as tested/asseAs per Installation and Product specifications, as tested/assessedVisualSame typeM/R


Frequency






Inspection - Personnel


- The inspection body shall define and document the competence requirements for all personnel involved in inspection activities, including requirements for education, training, technical knowledge, skills and experience.
- The inspection body shall make clear to each person their duties, responsibilities and authorities.
- The inspection body shall have documented procedures for selecting, training, formally authorizing, and monitoring inspectors and other personnel involved in inspection activities.
- Each inspector shall be observed on-site, unless there is sufficient supporting evidence that the inspector is continuing to perform competently.





Inspection - Report

- identification of the issuing body;
- unique identification and date of issue;
- > date(s) of inspection;
- identification of the item(s) inspected;
- signature or other indication of approval, by authorized personnel;
- > a statement of conformity where applicable;
- > the inspection results







THANK YOU FOR YOUR ATTENTION